

Wastewater Discharge Monitoring Short Report

For DNR Use Only

Facility Name : MADISON KIPP CORP
 Contact Address : □□
 □□ , □□
 Facility Contact : , □□
 Phone Number : □□
 Reporting Period : 07/01/2018 - 09/30/2018
 Form Due Date : 10/21/2018
 Permit Number : **0046566**

Date Received:
 DOC: 408712
 FIN: 7960
 FID: 113125320
 Region: South Central Region
 Permit Drafter: Drafter not set
 Reviewer: Emily M James
 Office: Milwaukee

Sample Point	Parameter #	Parameter	Date Sample	Sample Type	Sample Results	Units	Limit Type	Limit	LOD	LOQ	QC Exceed?	Lab Certification
001	377	pH Field	09/27/2018	GRAB	7.36	su	Daily Max Daily Min	9(0) 6(0)			N	
001	651	Oil & Grease (Hexane)	09/04/2018	GRAB	<1.4	mg/L	Daily Max	10(0)	1.4	5.1	N	999580010
001	457	Suspended Solids, Total	09/04/2018	GRAB	2.5	mg/L	Daily Max	40(0)			N	999580010
001	393	PAHs	09/04/2018	GRAB	0.075	ug/L	Monthly Avg	0.10(0)			N	998020430
001	44	Benzo(a)pyrene	09/04/2018	GRAB	<0.024	ug/L	Monthly Avg	0.10(0)	0.024	0.049	N	998020430
001	307	Naphthalene	09/04/2018	GRAB	<0.049	ug/L	Monthly Avg	70(0)	0.049	0.098	N	998020430

Wastewater Discharge Monitoring Short Report

Footnotes (DNR Use Only; Instructions for completing this form that are unique for your facility may be displayed here.)

General Remarks

pH was not previously required for this DMR submittal.

Laboratory Quality Control Comments

TSS is an approximate value as the reported concentrations was less than the LOQ but greater than the LOD.

The only Group 10 PAH parameter detected was Phenanthrene which is an approximate value as the reported concentration is less than the LOQ and greater than the LOD. In addition, Phenanthrene was reported in the blank.

Submitted by astehn on 10/18/2018 8:22:45 AM